

Wisconsin Department of Health Services

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 0011084	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____	(X3) DATE SURVEY COMPLETED 08/21/2025
NAME OF PROVIDER OR SUPPLIER MYSTIC MEADOWS LLC		STREET ADDRESS, CITY, STATE, ZIP CODE 14150 COUNTY ROAD C HILLSBORO, WI 54634		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
M 000	INITIAL COMMENTS On 08/21/2025, Surveyor conducted an abbreviated licensing survey at Mystic Meadows LLC, an AFH located in Hillsboro, WI. As a result of the survey, 1 violation of Chapter DHS 88 was issued. Census: 4	M 000		
M 276	88.05(3)(a) Homelike Environment An adult family home shall be safe, clean and well-maintained and shall provide a homelike environment. This Rule is not met as evidenced by: Based on observation and interview, the provider did not ensure that the environment was safe, clean and well maintained. There were combustibles in front of the furnace, food was stored on the floor of the pantry and there was a hole in Resident 1's door. Findings include: On 08/21/2025 at 9:30 AM, Surveyor toured the physical environment. Findings include: There was food observed stored on the floor of the pantry. There was a box of potato chips, bag	M 276		

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

Wisconsin Department of Health Services

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 0011084	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____	(X3) DATE SURVEY COMPLETED 08/21/2025
NAME OF PROVIDER OR SUPPLIER MYSTIC MEADOWS LLC		STREET ADDRESS, CITY, STATE, ZIP CODE 14150 COUNTY ROAD C HILLSBORO, WI 54634		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
M 276	Continued From page 1 of potatoes, cans of soda, and boxes of cereal on the floor of the pantry. There were combustible items next to the furnace. there as a mattress leaning up against the furnace, 3 plastic storage bins within 1 food of the furnace. There was a hole in Resident 1's door measuring approximately 2 inches by 2 inches. On 08/21/2025 at 10:30 AM, Surveyor interviewed Manager A. Manager A acknowledged that food should not be stored on the floor. Manager A acknowledged that there were several food items on the floor of the pantry and that the items would be moved as soon as possible. Manager A acknowledged that combustible items should not be stored within 3 feet of the furnace or water heater. Manager A stated that someone just set the items in front of the furnace without thinking. Manager A stated that Resident 1 has property destruction as a behavior but did not know when the hole was made.	M 276		