

Wisconsin Department of Health Services

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 0019150	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____	(X3) DATE SURVEY COMPLETED C 11/05/2025
NAME OF PROVIDER OR SUPPLIER 1925 TAFT AVE STABLE LIVING LLP		STREET ADDRESS, CITY, STATE, ZIP CODE 1925 TAFT AVE EAU CLAIRE, WI 54701		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
M 000	INITIAL COMMENTS On 11/04/2025, Surveyor conducted an abbreviated survey and 2 complaint investigations at 1925 Taft Ave Stable Living LLP. Data collection continued through 11/05/2025. Both complaints were unsubstantiated. One deficiency was identified. Census: 4	M 000		
M 278	88.05(3)(b) FREE OF HAZARDS The home shall be free from hazards and kept uncluttered and free of dangerous substances, insects and rodents. This Rule is not met as evidenced by: Based on observation and interview, the provider did not ensure the home was free from hazards when the furnace room had papers near the furnace, increasing the risk for fire. Findings include: On 11/04/2025, at 3:17 PM, Surveyor observed the furnace room with a small stack of papers sitting next to the furnace. The corners of the papers had started to crinkle and had slight yellow discoloration. It appeared the papers were manipulated by the heat of the furnace. At approximately 4:00 PM, Surveyor observed the	M 278		

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

Wisconsin Department of Health Services

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 0019150	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____		(X3) DATE SURVEY COMPLETED C 11/05/2025
NAME OF PROVIDER OR SUPPLIER 1925 TAFT AVE STABLE LIVING LLP			STREET ADDRESS, CITY, STATE, ZIP CODE 1925 TAFT AVE EAU CLAIRE, WI 54701		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETE DATE
M 278	Continued From page 1 furnace room with Manager A and shared concerns related to the papers located near the furnace. Manager A removed the papers and indicated s/he would find a different location to store the papers. The provider did not ensure the home was free from hazards when the furnace room had papers near the furnace that increased the risk for fire.	M 278			