Wisconsin Department of Health Services

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:	(X2) MULTIPLE CONSTRUCTION	(X3) DATE SURVEY COMPLETED
	0015147	A. BUILDING: _____ B. WING _____	11/13/2025

NAME OF PROVIDER OR SUPPLIER	STREET ADDRESS, CITY, STATE, ZIP CODE
ROWAN TRAIL	237 W SEWARD STREET POYNETTE, WI 53955

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
N 000	Initial Comments On 11/13/2025, Surveyors conducted an abbreviated licensing survey at Rowan Trail, a CBRF located in Poynette, WI. As a result of the survey, 1 violation of Chapter DHS 83 was issued. Census: 7	N 000		
N 640	83.59(2)(b) Solid core wood doors or equivalent A solid core wood door or an equivalent fire resistive door shall be provided at any interior stair between the basement and the first floor. The door shall have a positive latch and an automatic closing device and normally shall be kept closed. Enclosed furnace and laundry areas with self-closing doors in a split level home may substitute for the self-closing door between the first and second levels. Enclosed furnace and laundry areas shall have self-closing solid core wood doors or an equivalent fire resistive door when located on a common level with resident bedrooms. This Rule is not met as evidenced by: Based on observation and interview, the provider did not ensure that the laundry room door was able to self-close and latch. The laundry room door was unable to be closed due to a recent purchase of new clothes washers and dryers. Findings include: On 11/13/2025 at 10:00 AM, Surveyors observed the physical environment. The laundry room door was unlocked and open. There were 2 clothes dryers in the room. The	N 640		

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE | TITLE | (X6) DATE

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:	(X2) MULTIPLE CONSTRUCTION	(X3) DATE SURVEY COMPLETED
	0015147	A. BUILDING: _____ B. WING _____	11/13/2025

NAME OF PROVIDER OR SUPPLIER	STREET ADDRESS, CITY, STATE, ZIP CODE
ROWAN TRAIL	237 W SEWARD STREET POYNETTE, WI 53955

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
N 640	Continued From page 1 laundry room is on the main level which is the same level as resident apartments. On 11/13/2025 at 11:00 AM, Surveyors interviewed Manager A. Manager A stated that the facility had just bought new clothes washers and dryers and they were too big for the room causing the door to not be able to close and latch. Manager A acknowledged that the laundry room is on the same level as resident apartments and the door is required to self-close and latch. Manager A stated that s/he would contact maintenance and have the door open the opposite way so that it is able to self-close and latch.	N 640		