

Wisconsin Department of Health Services

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 0016899	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____	(X3) DATE SURVEY COMPLETED C 04/21/2026
NAME OF PROVIDER OR SUPPLIER ALBERTINE HOUSE 1		STREET ADDRESS, CITY, STATE, ZIP CODE 7925 N RIVER VIEW CT A MILWAUKEE, WI 53224		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
M 000	INITIAL COMMENTS On 04/21/2026, Surveyor conducted a standard survey and one complaint investigation. One deficiency was identified. One complaint was unsubstantiated. Census: 04	M 000		
M 278	88.05(3)(b) FREE OF HAZARDS The home shall be free from hazards and kept uncluttered and free of dangerous substances, insects and rodents. This Rule is not met as evidenced by: Based on observation and interview, the facility failed to ensure 1 of 1 clothes dryer vent was maintained. Dryer vent was not attached at the base of the dryer which allowed the dryer to exhaust directly into the laundry room. Findings include: On 04/21/2026, Surveyor conducted a standard survey. Surveyor toured the physical environment which included 1 laundry area with 1 clothes dryer on the main floor. The dryer was located against the west wall, in a room off the kitchen. The dryer vent extended approximately 6 inches from the back of dryer. It was not connected to the outside vent which allowed the dryer to exhaust directly into the laundry room.	M 278		

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

Wisconsin Department of Health Services

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 0016899	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____		(X3) DATE SURVEY COMPLETED C 04/21/2026
NAME OF PROVIDER OR SUPPLIER ALBERTINE HOUSE 1		STREET ADDRESS, CITY, STATE, ZIP CODE 7925 N RIVER VIEW CT A MILWAUKEE, WI 53224			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETE DATE
M 278	Continued From page 1 On 04/21/2026, at approximately 4:00 PM, Surveyor described the above findings to Licensee A. Licensee A stated they were not aware the vent was not attached to the dryer, but they would have it fixed it immediately.	M 278			