

Wisconsin Department of Health Services

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 0018744	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING _____	(X3) DATE SURVEY COMPLETED R-C 06/25/2024
--	--	---	---

NAME OF PROVIDER OR SUPPLIER SAVED BY GRACE FAITH ADULT FAMILY HOM	STREET ADDRESS, CITY, STATE, ZIP CODE 3845 NORTH 10TH STREET MILWAUKEE, WI 53206
--	--

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
M 000	<p>INITIAL COMMENTS</p> <p>From 06/14/2024 to 06/25/2024, Surveyor conducted a complaint investigation, verification visit, and standard survey at Saved By Grace Faith Adult Family Home LLC.</p> <p>One deficiency was identified.</p> <p>All violations from statement of deficiency (SOD) S3CO11, dated 03/24/2023 were substantially corrected.</p> <p>The complaint was unsubstantiated.</p> <p>Under statutory provisions of Wis. Stat. Ch. 50, a \$200 revisit fee is being assessed.</p> <p>Census: 4</p>	M 000		
M 570	<p>88.10(3)(l) Safe Physical Environment</p> <p>Individuals, except for correctional residents, have basic rights which they do not lose when they enter an adult family home. A resident shall have a safe environment in which to live. The adult family home shall safeguard residents who cannot fully guard themselves from environmental hazards to which they are likely to be exposed, including conditions which would be hazardous to anyone and conditions which would be or are hazardous to a particular resident because of the resident's condition or disability.</p> <p>This Rule is not met as evidenced by: Based on observation and interview, the provider did not safeguard residents from environmental hazards when 1 of 1 resident bathroom faucet</p>	M 570		

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

Wisconsin Department of Health Services

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 0018744	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING _____	(X3) DATE SURVEY COMPLETED R-C 06/25/2024
--	--	---	---

NAME OF PROVIDER OR SUPPLIER SAVED BY GRACE FAITH ADULT FAMILY HOM	STREET ADDRESS, CITY, STATE, ZIP CODE 3845 NORTH 10TH STREET MILWAUKEE, WI 53206
--	--

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
M 570	<p>Continued From page 1</p> <p>reached an unsafe water temperature of 142 degrees Fahrenheit (F).</p> <p>Findings include:</p> <p>The provider is a licensed ambulatory adult family home (AFH) that may serve up to 4 residents in any of the following client groups: emotionally disturbed/mental illness, irreversible dementia/Alzheimer's, traumatic brain injury, advanced aged, alcohol/drug dependent, correctional clients, and developmentally disabled.</p> <p>On 06/14/2024, at 10:16 AM, Surveyor measured the hot water of the provider's bathroom sink. One of 1 faucet had hot water that was 142 degrees F. This bathroom was available to all residents in the home.</p> <p>On 06/14/2024 at 10:35 AM, Surveyor interviewed Administrator A. Administrator A confirmed the water temperature was too hot and created a risk to residents. Administrator A stated staff at times would turn up the water heater. Administrator A stated s/he would reeducate staff and adjust the water heater immediately.</p> <p>Exposure to hot water is a potential environmental danger for residents. Elderly residents and residents with mental and physical disabilities may have neurological conditions that prevent instant recoil from hot water. Because these individuals do not instantly react to dangerous temperature levels, they are at particular risk for injury. Hot water can cause scalding; e.g., second and third degree burns in which the skin blisters and swells. In such instances, skin does not return to normal and forms scar tissue upon healing. These burns may</p>	M 570		

Wisconsin Department of Health Services

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 0018744	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING _____	(X3) DATE SURVEY COMPLETED R-C 06/25/2024
--	--	---	---

NAME OF PROVIDER OR SUPPLIER SAVED BY GRACE FAITH ADULT FAMILY HOM	STREET ADDRESS, CITY, STATE, ZIP CODE 3845 NORTH 10TH STREET MILWAUKEE, WI 53206
--	--

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
M 570	Continued From page 2 lead to permanent disability. (DQA Publication-01942, Hot Water Temperatures in Adult Family Homes, August 2017.)	M 570		